



By Royal Charter

Kitemark™ Certificate

This is to certify that:

Zhejiang Orientx Fire Safety
Equipment Co., Ltd.
Wucheyan
Huangjiabu Town
Yuyao
Zhejiang
315466
China

Holds Certificate Number:

KM 503518

In respect of:

BS EN 3 Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 05/01/2007

Latest Issue: 06/10/2016



Page: 1 of 5

...making excellence a habit.™

This certificate has been issued by and remains the property of BSI Management Systems Certification (Beijing) Company Limited, Room No. 2008, East Ocean Center No. 24A, Jianguomenwai, Beijing 10004 and should be returned immediately upon request.
To check its validity telephone +86 21 64 31 2638. An electronic certificate can be authenticated [online](#).

Head Office: BSI Assurance UK Limited, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes, MK5 8PP, UK. Registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, United Kingdom.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 503518

Model Number	Description
PG1	1 kg 70% ABC powder, stored pressure. Fire rating 8A & 34B
PG1A	1 kg 40% ABC powder, stored pressure. Fire rating 5A & 34B
PG1B	1 kg 40% ABC powder, stored pressure. Fire rating 8A & 34B
PG1C	1 kg 40% ABC powder, stored pressure. Fire rating 5A & 34B
PG1D	1 kg 70% ABC powder, stored pressure. Fire rating 8A & 34B
PG1R	1 kg 30% ABC powder, stored pressure. Fire rating 8A & 34B
PG2	2 kg 70% ABC powder, stored pressure. Fire rating 13A & 70B
PG2A, DP2E(PG2A)	2 kg 40% ABC powder, stored pressure. Fire rating 13A & 70B
PG2C	2 kg 40% ABC powder, stored pressure. Fire rating 13A & 70B
PG2D	2 kg 70% ABC powder, stored pressure. Fire rating 13A & 70B
PG2R	2 kg 30% ABC powder, stored pressure. Fire rating 13A & 70B
PG3R	3 kg 30% ABC powder, stored pressure. Fire rating 21A & 89
PG4	4 kg 70% ABC powder, stored pressure. Fire rating 27A & 113B
PG4A, DP4E(PG4A)	4 kg 40% ABC powder, stored pressure. Fire rating 21A & 89B
PG4B	4 kg 40% ABC powder, stored pressure. Fire rating 21A & 89B
PG4C	4 kg 70% ABC powder, stored pressure. Fire rating 27A & 113B
PG4R	4 kg 30% ABC powder, stored pressure. Fire rating 27A & 113B
PG6	6 kg 70% ABC powder, stored pressure. Fire rating 34A & 183B
PG6A, DP6E(PG6A)	6 kg 40% ABC powder, stored pressure. Fire rating 27A & 144B
PG6B	6 kg 40% ABC powder, stored pressure. Fire rating 34A & 183B
PG6C	6 kg 90% ABC powder, stored pressure. Fire rating 55A & 233B
PG6D	6 kg 70% ABC powder, stored pressure. Fire rating 34A & 183B
PG6E	6 kg 40% ABC powder, stored pressure. Fire rating 27A & 144B
PG6F	6 kg 70% ABC powder, stored pressure. Fire rating 34A & 183B

First Issued: 05/01/2007

Latest Issue: 06/10/2016

Page: 2 of 5

This certificate has been issued by and remains the property of BSI Management Systems Certification (Beijing) Company Limited, Room No. 2008, East Ocean Center No. 24A, Jianguomenwai, Beijing 10004 and should be returned immediately upon request.
To check its validity telephone +86 21 64 31 2638. An electronic certificate can be authenticated [online](#).

Head Office: BSI Assurance UK Limited, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes, MK5 8PP, UK. Registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, United Kingdom.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 503518

Model Number	Description
PG6J	6 kg ABC powder (50% MAP), stored pressure, copper alloy valve. Fire rating 55A & 233B
PG6M	6 kg 50% ABC powder, stored pressure, aluminium valve. Fire rating 55A & 233B
EP60	6 kg 70% ABC powder, stored pressure. Fire rating 34A & 183B
EP60A	6 kg 40% ABC powder, stored pressure. Fire rating 27A & 144B
P6GH	6 kg 30% ABC powder, stored pressure, copper alloy valve, rolled cylinder. Fire rating 43A & 233B
P6GJ	6 kg 30% ABC powder, stored pressure, copper alloy valve, rolled cylinder. Fire rating 55A & 233B
P6GK	6 kg 30% ABC powder, stored pressure, aluminium valve, rolled cylinder. Fire rating 43A & 233B
P6GM	6 kg 30% ABC powder, stored pressure, aluminium valve, rolled cylinder. Fire rating 55A & 233B
PG6Q	6 kg 50% ABC powder, stored pressure. Fire rating 55A & 233B
PG6R	6 kg 30% ABC powder, stored pressure. Fire rating 43A & 233B
PG9	9 kg 70% ABC powder, stored pressure. Fire rating 55A & 233B
PG9A, DP9E(PG9A)	9 kg 40% ABC powder, stored pressure. Fire rating 34A & 233B
PG9B	9 kg 40% ABC powder, stored pressure. Fire rating 55A & 233B
PG9C	9 kg 40% ABC powder, stored pressure. Fire rating 34A & 233B
PG9D	9 kg 70% ABC powder, stored pressure. Fire rating 55A & 233B
PG9E	9 kg 40% ABC powder, stored pressure. Fire rating 34A & 233B
PG9F	9 kg 70% ABC powder, stored pressure. Fire rating 55A & 233B
PG9H	9 kg 20% ABC powder, stored pressure, copper alloy valve. Fire rating 34A & 233B
PG9J	9 kg 20% ABC powder, stored pressure, aluminium valve. Fire rating 34A & 233B
PG9R	9 kg 30% ABC powder, stored pressure. Fire rating 55A & 233B
EP90	9 kg 70% ABC powder, stored pressure. Fire rating 55A & 233B
EP90A	9 kg 40% ABC powder, stored pressure. Fire rating 34A & 233B
PG12	12 kg 70% ABC powder, stored pressure. Fire rating 55A & 233B

First Issued: 05/01/2007

Latest Issue: 06/10/2016

Page: 3 of 5

This certificate has been issued by and remains the property of BSI Management Systems Certification (Beijing) Company Limited, Room No. 2008, East Ocean Center No. 24A, Jianguomenwai, Beijing 10004 and should be returned immediately upon request.
To check its validity telephone +86 21 64 31 2638. An electronic certificate can be authenticated [online](#).

Head Office: BSI Assurance UK Limited, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes, MK5 8PP, UK. Registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, United Kingdom.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 503518

Model Number	Description
F2	2 litre foam (3% AFFF), stored pressure. Fire rating 5A & 34B
F2R	2 litre foam (3% AFFF), stored pressure. Fire rating 8A & 55B
F3	3 litre foam (3% AFFF), stored pressure. Fire rating 8A & 55B
F3A	3 litre foam (3% AFFF), stored pressure. Fire rating 8A & 55B
F3R	3 litre foam (3% AFFF), stored pressure. Fire rating 13A & 70B
F6	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
F6A	6 litre foam (6% AFFF), stored pressure. Fire rating 21A and 144B
F6B	6 litre foam (5% AFFF), stored pressure. Fire rating 34A and 113B
F6C	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
F6E	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
F6H	6 litre foam (15% INILAM AX + 1.5% I SC-6), stored pressure, copper alloy valve. Fire rating 34A & 233B
F6J	6 litre foam (15% INILAM AX + 1.5% I SC-6), stored pressure, aluminium valve. Fire rating 34A & 233B
F6R	6 litre foam (3% AFFF), stored pressure. Fire rating 21A & 144B
EF60	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
F9, FS9E(F9)	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 183B
F9A	9 litre foam (6% AFFF), Stored pressure. Fire rating 34A and 233B
F9B	9 litre foam (5% AFFF), stored pressure. Fire rating 43A and 183B
F9C	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 183B
F9D	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 183B
F9H	9 litre foam (15% INILAM AX + 1.5% I SC-6), stored pressure, copper alloy valve. Fire rating 43A & 233B
F9J	9 litre foam (15% INILAM AX + 1.5% I SC-6), stored pressure, aluminium valve. Fire rating 43A & 233B
F9R	9 litre foam (3% AFFF), stored pressure. Fire rating 27A & 183B
EF90	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 183B

First Issued: 05/01/2007

Latest Issue: 06/10/2016

Page: 4 of 5

This certificate has been issued by and remains the property of BSI Management Systems Certification (Beijing) Company Limited, Room No. 2008, East Ocean Center No. 24A, Jianguomenwai, Beijing 10004 and should be returned immediately upon request.
To check its validity telephone +86 21 64 31 2638. An electronic certificate can be authenticated [online](#).

Head Office: BSI Assurance UK Limited, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes, MK5 8PP, UK. Registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, United Kingdom.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 503518

Model Number	Description
W6	6 litre water, stored pressure. Fire rating 13A
W6C	6 litre water, stored pressure. Fire rating 13A
W6D	6 litre water, stored pressure. Fire rating 13A
W6E	6 litre water + additive (10% HYDROSPRAY 13C), stored pressure. Fire rating 21A
W6R	6 litre water + additive, stored pressure. Fire rating 21A
W9, WS9E(W9)	9 litre water, stored pressure. Fire rating 13A
W9C	9 litre water, stored pressure. Fire rating 13A
W9E	9 litre water, stored pressure. Fire rating 13A
W9R	W9 litre water + additive, stored pressure. Fire rating 27A
EW90	9 litre water, stored pressure. Fire rating 13A
W2F	2 l wet chemical, stored pressure. Fire rating 8A & 40F
W6F	6 l wet chemical, stored pressure. Fire rating 13A & 75F
OCE2-LWB117	2 kg carbon dioxide with round swivel horn. Aluminium cylinder. Fire rating 34B
OCE5-LWB152	5 kg carbon dioxide with oval horn. Aluminium cylinder. Fire rating 70B
Orex K2	2 kg carbon dioxide, steel body, fixed horn. Fire rating 34B
Orex K5	5 kg carbon dioxide, steel body, round horn. Fire rating 89B
K5C	5 kg carbon dioxide, steel body, oval horn. Fire rating 89B
K2, CO2E(K2)	2 kg carbon dioxide. Fire rating 34B
K5, CO5E(K5)	5 kg carbon dioxide. Fire rating 70B

All the above products are certified to BS EN 3-7:2004+A1:2007.

The above portable fire extinguisher models manufactured by Zhejiang Orientx Fire Safety Equipment Co., Ltd. falling within the scope of this certificate may be marketed under the following brand names:

ORIENTX

First Issued: 05/01/2007

Latest Issue: 06/10/2016

Page: 5 of 5

This certificate has been issued by and remains the property of BSI Management Systems Certification (Beijing) Company Limited, Room No. 2008, East Ocean Center No. 24A, Jianuomenwai, Beijing 10004 and should be returned immediately upon request.
To check its validity telephone +86 21 64 31 2638. An electronic certificate can be authenticated [online](#).

Head Office: BSI Assurance UK Limited, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes, MK5 8PP, UK. Registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, United Kingdom.
A member of BSI Group of Companies.